LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

## Cable ID: KW/SSTP/GN/2M-M03

**Test Summary: PASS**

Date / Time: 06/03/2026 10:49:17 AM
**Headroom 3.5 dB (NEXT 1,2-4,5)**
**Test Limit: ISO Patch Cord Cat6A 2.0m**
Cable Type: Cat 6A S/FTP
NVP: 77.0%


Software Version: V6.13 Build 2
Limits Version: V7.11
Calibration Date:
Main (Module): 07/07/2025
Remote (Module): 07/07/2025

Model: DSX-5000
Main S/N: 3471249
Remote S/N: 3471253
Main Adapter: DSX-PC6A
Remote Adapter: DSX-PC6A

| | | |
|---|---|---|
| Length (ft) | [Pair 1,2] | 8 |
| Prop. Delay (ns) | [Pair 3,6] | 10 |
| Delay Skew (ns) | [Pair 1,2] | 0 |
| Resistance (ohms) | [Pair 7,8] | 0.64 |

| | Worst Case Margin | | Worst Case Value | |
|---|---|---|---|---|
| **PASS** | MAIN | SR | MAIN | SR |
| Worst Pair | 3,6-4,5 | 1,2-4,5 | 1,2-4,5 | 3,6-4,5 |
| **NEXT (dB)** | 3.6 | 3.5 | 4.2 | 3.9 |
| Freq. (MHz) | 247.0 | 396.0 | 451.0 | 485.0 |
| Limit (dB) | 38.8 | 33.6 | 32.2 | 31.4 |

| **PASS** | MAIN | SR | MAIN | SR |
|---|---|---|---|---|
| Worst Pair | 3,6 | 3,6 | 3,6 | 3,6 |
| **RL (dB)** | 2.1 | 2.3 | 3.6 | 3.4 |
| Freq. (MHz) | 317.0 | 317.0 | 473.0 | 475.0 |
| Limit (dB) | 12.5 | 12.5 | 9.8 | 9.8 |




Wire Map (T568B)
**PASS**

